



Industrie Service

Herewith is granted the right to the company

Rosenberg Ventilatoren GmbH

in

D-74653 Künzelsau - Gaisbach

for the operated fan test rig

„Großer Prüfstand“

located in

D-74653 Künzelsau – Gaisbach

for the volumetric flow range of 3,000 m³/h to 40,000 m³/h and a pressure range up to 1,500 Pa,

based on the positive results of the completed inspection regarding compliance with the requirements of the Standard

DIN EN ISO 5801:2018-04

to identify this with the following TÜV SÜD Certification Mark.



This certificate is valid until 2024-12-31

Certificate Registration Number: 08/11/01



Certification Body for products
Refrigeration and air-conditioning
Munich, 2022-11-30





Industrie Service

Herewith is granted the right to the company

Rosenberg Ventilatoren GmbH

in

D-74653 Künzelsau - Gaisbach

for the operated fan test rig

„Mittlerer Prüfstand“

located in

D-74653 Künzelsau – Gaisbach

for the volumetric flow range of 100 m³/h to 11,000 m³/h and a pressure range up to 2,000 Pa,

based on the positive results of the completed inspection regarding compliance with the requirements of the Standard

DIN EN ISO 5801:2018-04

to identify this with the following TÜV SÜD Certification Mark.



This certificate is valid until 2024-12-31

Certificate Registration Number: 08/11/02



Certification Body for products
Refrigeration and air-conditioning
Munich, 2022-11-30

